

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 01:09 pm

**PWS ID:** UTAH28011      **Name:** CAPITOL REEF NATIONAL PARK  
**Legal Contact:** NPS - CAPITOL REEF NATIONAL PARK      **Rating:** Approved  
AL HENDRICKS      **Rating Date:** 01/31/1985  
**Address:** HC 70 BOX 15      **Activity Status:** Active  
TORREY, UT 84775  
**Phone Number:** 435-425-3791  
**City Served (Area):**  
**County:** WAYNE COUNTY  
**System Type:** Community      **Last Inv Update:** 06/21/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 04/04/2009      **Total Dsgn Cap:**  
**Population:** 1,081      **Surveyor:** ROGER FOISY      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	HENDRICKS, AL	SUPERINTEND	435-425-3791		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	15
Commercial	Unknown	0	12
Agricultural	Unknown	0	2
			29 Total Svc Connections

### Storage

**Total Storage:** 100,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	100000 GALLON	Ground	100,000 GAL	Concrete		A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	FREMONT RIVER WTP		I	
TP002	1992 WELL RO AND CHLORINATOR		A	
TP003	1992 WELL RO PLANT		I	

### Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	CHLORINATOR PUMP STATION	A		P			

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

---

## Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	FREMONT RIVER INTAKE	Inactive	IN				Yes	SW	Other		
WS002	1992 WELL	Active	WL	6	40 GPM	42 GPM	Yes	GW	Permanent	1/1 to 12/31	

*\*Reports measured flow for wells, approved design capacity for all other sources.*